

# FIRE SAFETY AUDIT REPORT

## 1. Details of the Building being certified:

1	Name and address of the Building	M/s. CGR International school, Plot No. 99 & 100, Ayyappa Society, Madhapur, Serilingampally Mandal, Ranga Reddy District.
2	Name and address of the Association	M/s. CGR International school, Plot No. 99 & 100, Ayyappa Society, Madhapur, Serilingampally Mandal, Ranga Reddy District.
3	Name and address of the responsible person with Telephone No. and mail ID	Sri C. Abhishek Reddy, Plot No. 99 & 100, Ayyappa Society, Madhapur, Serilingampally Mandal, Ranga Reddy District. Contact No. 9848169444 Email Id: abhishek.choppa@hotmail.com
4	Date of Inspection Report	07.11.2023

## 2. Building Details:

- Height of the building (in meters) : 21.15 Mtrs
- Floor Wise Occupancy details: Cellar + Ground + 05 Upper floors for Educational Occupancy (B-1).

Sl. N	Floor	Built-up area in Sq. Meters	Type of Occupancy	Occupant load
1	Cellar	663.14	Parking	-
2	Ground	639.17	Educational (B-1)	82.00
3	1 <sup>st</sup> floor	639.17	Educational (B-1)	82.00
4	2 <sup>nd</sup> floor	639.17	Educational (B-1)	82.00
5	3 <sup>rd</sup> floor	639.17	Educational (B-1)	82.00
6	4 <sup>th</sup> floor	639.17	Educational (B-1)	82.00
7	5 <sup>th</sup> floor	639.17	Educational (B-1)	82.00
	Total	4498.16		

## Details of the Third Party Auditor:

Name of the Auditor : Sri Saleem Khan  
Designation : (District Fire Officer (Retired) Hyderabad),  
Address & Mobile No : D. No 8-1-364/A/66, Office No 303, 3rd Floor,  
Adams Colony, Beside Podium Mall, Tolichowki,  
Hyderabad.

Registration Details if any: Telangana Retired Fire Officers Association.  
(Regd No.915 of 2017).

(Cont...2)

*A. H. Khan*  
*7/11/23*  
**SALEEM KHAN**  
DISTRICT FIRE OFFICER (Rtd)  
HYDERABAD

### 3. Assessment of Fire Safety Measures:

Certified that, I/We have carried out an inspection of the following Fire Prevention and Life Safety Measures installed in the building/premises on 07.11.2023 and furnish the following:-

S. N	Fire Fighting Systems	Provide as per Occupancy NOC	Now Available	Remark working /Not working
1	Fire Extinguishers	18 Nos.	18 Nos.	working
2	Hose Reel	07 Nos.	07 Nos.	working
3	Wet Raiser/Down Comer	Required	Provided 01 No.	working
4	Yard Hydrant	NA	NA	Nil
4	Manually Operated Electric Alarm System	07 Nos.	07 Nos.	Nil
5	Automatic Sprinklers system	Required	13 Nos.	Nil
6	Automatic Detection and Alarm System	NA	NA	Nil
7	Underground static water storage tank	NA	NA	Nil
8	Terrace Tank	10,000 ltrs	10,000 ltrs	Working/ Found Full capacity
9	Fire Pumps:	NA	NA	Nil
10	Two Way Inlet	Required 01 No.	Provided 01 No.	Checked
11	Terrace Pump	01 No. Booster Pump 450 LPM	01 No. Booster Pump 450 LPM	Working
12	Exit signs	Required	Provided	Nil
13	Emergency lighting with Battery backup for minimum 90 minutes	NA	NA	Nil
14	Fire shaft pressurization system	NA	NA	Nil
15	Fire Doors whether maintained in operable condition.	NA	NA	Nil

I further certify that I have checked the working condition of these installations in the above-mentioned building, found in good working condition, and these are maintained in good repair and efficient condition as on Dt. 07-11-2023, as required under the provisions of the Telangana Fire Services Act, 1999. If any deviation is found in the above report I may be held responsible for the same and necessary action may be taken.

Place: Hyderabad.

Date: 07-11-2023.

Signature and Address of the Third Party

Fire Safety Auditor

DISTRICT FIRE OFFICER  
HYDERABAD

**AUDITOR**  
**GOVT. APPROVED**  
**T.S. HYDERABAD**



NO.: FC-1202-1123-0002

## FIRE MITIGATION/SAFETY CERTIFICATE

CGR International school TIN NO: NA ,Cell No.9848169444, Address: Plot No. 99 & 100,  
Ayyappa Society, Madhapur, Serilingampally Mandal, Ranga Reddy District. Shop

/Establishment is installed with following fire safety measures :

- 1) Fire Extinguishers: i)ABC(Powder)- 16 In Nos ii)CO2 -2 In Nos iii)Foam-0 In Nos
- 2) Smoke Detectors: i)Battery Operated -0 In Nos ii)Electric Operated-0 In Nos



Signature & Seal:

Date: 15-Nov-2023

Issued by: Md.Mustafa  
AMY Fire Consultancy Regd.No  
36FFMPB9770J1ZU  
"2nd Floor, 8-1-423/A/161 Flat  
No 202, Diamond Hills,  
Shaikpet,  
Hyderabad, Hyderabad"

Cell No. 7093644913

\*\*The Fire Mitigation/Safety Certificate is valid for one (01) year from the date of issue and shall be renewed every year. It is the responsibility of the owner/occupier to apply for renewal before one month of its expiry.