NO.: FC-1202-1224-0007

FIRE MITIGATION/SAFETY CERTIFICATE

CGR International School TIN NO: NA, Cell No. 9848169444, Address: Plot No. 99 & 100, Ayyappa Society, Madhapur, Serilingampally Mandal, Ranga Reddy District. Shop/Establishment is installed with following fire safety measures :

1) Fire Extinguishers: i) ABC(Powder)- 14 In Nos ii) CO2 - 2 In Nos iii) Foam- 2 In Nos

2) Smoke Detectors: i) Battery Operated -0 In Nos ii) Electric Operated-0 In Nos



Issued by: Md. Mustafa AMY Fire Consultancy Regd.No. 36FFMPB9770J1ZU "2nd Floor, 8-1-423/A/161 Flat No 202, Diamond Hills, Shaikpet, Hyderabad. Cell No. 7093644913

**The Fire Mitigation/Safety Certificate is valid for one (01) year from the date of issue and shall be renewed every year. It is the responsibility of the owner/occupier to apply for renewal before one month of its expiry.



1. Details of the Building being certifie

1	Name and address of the Building	M/s. CGR International school, Plot No. 99 & 100, Ayyappa Society, Madhapur, Serilingampally Mandal, Ranga Reddy District.	
2	Name and address of the Association	M/s. CGR International school, Plot No. 99 & 100, Ayyappa Society, Madhapur, Serilingampally Mandal, Ranga Reddy District.	
3	Name and address of the responsible person with Telephone No. and mail ID	Society, Madhapur, Serilingampally Mandal, Ranga Reddy District. Contact No. 9848169444	
4	Date of Inspection Report	Email Id: abhishek.choppa@hotmail.com 17.12.2024	

2. Building Details:

- i) Height of the building (in meters) : 21.15 Mtrs
- ii) Floor Wise Occupancy details: Cellar + Ground + 05 Upper floors for Educational Occupancy (B-1).

SI. N	Floor	Built-up area in Sq. Meters	Type of Occupancy	Occupant load
1	Cellar	663.14	Parking	-
2	Ground	639.17	Educational (B-1)	160.00
3	1 st floor	639.17	Educational (B-1)	160.00
4	2 nd floor	639.17	Educational (B-1)	160.00
5	3rd floor	639.17	Educational (B-1)	160.00
6	4 th floor	639.17	Educational (B-1)	160.00
7	5 th floor	639.17	Educational (B-1)	160.00
-	Total	4498.16	TC-2	

Details of the Third Party Auditor:

Name of the Auditor Designation

: Sri Saleem Khan

Designation

: (District Fire Officer (Retired) Hyderabad),

Address & Mobile No

: D. No 8-1-364/A/66, Office No 303, 3rd Floor, Adams Colony, Tolichowki, Hyderabad.

Registration Details if any; Telangana Retired Fire Officers Association.

(Regd No.915 of 2017).

Attented SALEEM KHAN DISTRICT FIRE OFFICER (R+d HYDERABAD

(Cont...2)

3. Assessment of Fire Safety Measures:

Certified that, I/We have carried out an inspection of the following Fire Prevention and Life Safety Measures installed in the building/premises on 17.12.2024 and furnish the following:-

S.	Fire Fighting Systems	Provided by the builder	Now Available	Remark working /Not working
N		18 Nos.	18 Nos.	working
1	Fire Extinguishers		07 Nos.	working
2	Hose Reel	07 Nos.	Provided 01 No.	working
3	Wet Raiser/Down Comer	Required		Nil
4	Yard Hydrant	NA	NA	
4	Manually Operated Electric Alarm System	07 Nos.	07 Nos.	working
5	Automatic Sprinklers system	Required	13 Nos.	working
6	Automatic Detection and	NA	NA	Nil
7	Alarm System Underground static water	NA	NA	Nil
8	storage tank Terrace Tank	10,000 ltrs	10,000 ltrs	Working/ Found Full capacity
9	Fire Pumps:	NA	NA	Nil
10	Two Way Inlet	Required 01 No.	Provided 01 No.	Checked
10	Terrace Pump	01 No. Booster Pump 450 LPM	01 No. Booster Pump 450 LPM	Working
12	Exit signs	Required	Provided	Checked
12	Emergency lighting with Battery backup for minimum 90 minutes	NA	NA	Nil

I further certify that I have checked the working condition of these installations in the above-mentioned building, found in good working condition, and these are maintained in good repair and efficient condition as on Dt. 17-12-2024, as required under the provisions of the Telangana Fire Services Act, 1999. If any deviation is found in the above report I may be held responsible for the same and necessary action may be taken.

Place: Hyderabad. Date: 17-12-2024.

12/24 Signature DIS ird Pá Hor.

AUDITOR GOVT. APPROVED T.8. HYDERABAD

:: 2 ::